
Title

Field of Application for:
The ESD Ac43 30 & 60 minute
range of doorsets in timber based
door frames

For 30 & 60 minutes Fire
Resistance

Report No.:

BMT/CNA/F14098 Revision B

Issue Date:

22nd May 2024

Valid Until:

22nd May 2029

Job Reference:

WF543216

Prepared for:

Enfield Speciality Doors
276 – 278 Alma Road,
Enfield,
EN3 7BB
United Kingdom

10 Hardware

10.1 General

The following section details the permitted scope and constraints for fitting hardware to this door design. The following items of hardware must also bear the UKCA or CE Mark in addition to the requirements outlined in the following sections. The UKCA or CE mark must indicate that the hardware is suitable for fire doors in the classification code and declaration of performance issued by the hardware manufacturer:

- Latches & locks: Test Standard EN 12209
- Single axis hinges: Test Standard EN 1935
- Controlled door closing devices: Test Standard EN 1154
- Door co-ordinators: Test Standard EN 1158
- Emergency exit hardware: Test Standard EN 179
- Panic exit hardware: Test Standard EN 1125.

The following sections consider what tested and assessed alternative items of essential and non-essential hardware can be used on the doorset range.

Items of hardware have been considered and approved via the following means:

- The component has been successfully tested to BS 476: Part 22: 1987 or BS EN 1634-1 in a suitably similar type of doorset e.g. timber leaf in timber frame.
- As a result of an assessment of the appropriateness of the item of hardware, based on test evidence not commissioned by Enfield Speciality Doors.
- As a result of the Certifire approval of the item of hardware.

Each section will consider the named item of hardware and detail if there are any limitations associated with:

- Leaf size
- Configuration
- Intumescent seals
- Intumescent protection
- Frame configuration requirements

No item of hardware should be within 200mm of another item of hardware unless there is test evidence to demonstrate they can be in closer proximity.

Hardware items should generally be fitted in accordance with the manufacturer's instructions. **However, the parameters and requirements of this assessment always take precedence, including specified protection such as hardware gaskets.** Referenced Certifire approved hardware may be incorporated subject to the design, material and dimensional limitations identified within this assessment report and identified on the relevant Certifire certificate.

10.2 Intumescent to Hardware


The intumescent materials used to protect hardware that have been tested and assessed for this doorset design are detailed below. Note that any one of the product/manufacturer options listed in the table may be used in the specific application noted. However, only 1 No manufacturer should be considered per doorset application.

The door gap perimeter intumescent seal specifications are documented in conjunction with the leaf envelope size limitations in section 4.

| Hardware Intumescent Specification | | |
|------------------------------------|---|--------------------------|
| Item | Location | Product/Manufacturer |
| Hinges | Under each blade of the hinge. | 1.5 (t) Norseal Graphite |
| Lock/latches | Under forend & keep and encasing the latch body within the leaf. | 1 (t) Interdens ® |
| Handles & escutcheons | Lining the footprint of the handle and escutcheon. | 1 (t) Interdens ® |
| Flush bolts | Encasing the entire body of the flush bolt including the back surface of the face plate | 1 (t) Interdens ® |



Example of hinge protection detail



Example of lock & latch protection detail

Gaskets must be fitted where required by supporting evidence, for example, test evidence or Certifire certificates. If gaskets are not required by the supporting evidence but are within this Field of Application, the requirements of this Field of Application take precedence.

Where it is stated that intumescent is not required for a particular element of hardware, it is permitted to use up to 2mm thick MAP, Interdens or graphite-based gasket tested for the particular application [as appropriate for the hardware]. It is the opinion of Warringtonfire that the additional protection will not detract from the fire resistance performance under test conditions.

10.3 Essential Hardware

The following table details the essential hardware for the various doorset configurations that are referenced in this assessment.

| Configuration | Hardware |
|---------------|--|
| LSASD | <ul style="list-style-type: none">• Latch• Handle• Hinges• Self-closing device (closer) |
| ULSASD | <ul style="list-style-type: none">• Hinges• Self-closing device (closer) |
| LSADD | <ul style="list-style-type: none">• Latch• Handle• Hinges• Self-closing device (closer)• Flush bolt• Door Selector (where rebated meeting edges are used) |
| ULSADD | <ul style="list-style-type: none">• Hinges• Self-closing device (closer)• Door Selector (where rebated meeting edges are used) |

10.4 Latches & Locks

Unless explicitly detailed within the sections below only 1No. lock or latch shall be applied within any individual doorset. When fitted the lock or latch body shall be installed within the vertical edge of the door leaf in all cases, at a height as detailed within the relevant section below. Refer to specific notes contained within each section for further considerations on lock or latch type.

10.4.1 Single Point Engagement

The table below details the tested latches and locks that are approved.

| Element | Manufacturer & Product Reference |
|-----------------|--|
| Locks & latches | 1. Union ASSA Abloy Optimus3 mortice lock / latch Ref. JLZE21R-SS60 – BMT/FER/F13291 |

Alternatively, Certifire approved components with the following specification are also deemed acceptable.

| Element | Specification |
|--|--|
| Maximum forend and strike plate dimensions | 235mm high x 25mm wide x 4mm thick |
| Maximum body dimensions | 165mm high x 100mm wide x 18mm thick |
| Intumescent protection | see section 10.2 |
| Materials | All parts essential to the locking/latching action (including the latch bolt, forend and strike) to be steel, stainless steel or brass with a melting point $\geq 800^{\circ}\text{C}$ |

Notes:

1. In all instances the location of the handle must be between 825 – 1225mm from the threshold.

10.4.2 Cylinders

Components with the following specification are also deemed acceptable.

- Where required for use with single point latches, the cylinder must be constructed of either brass or steel with a melting point in excess of 800°C.
- The cylinder must be compatible with the lock/latch.
- Cylinder dimensions may be up to 33mm high x 17mm wide at the maximum dimension and may be of euro profile or oval.
- Single and double cylinders, along with cylinder & turn are permitted.
- Door preparation for single cylinders shall penetrate only 2/3rds of the door thickness.
- Intumescent protection and tightness of fitting:
 - As the lock body is protected with an intumescent material, maximum clearance between leaf and cylinder is 3mm to each edge.
 - 1mm thick MAP or non-pressure forming graphite intumescent around the cylinder is optionally permitted.

10.5 Handles

The table below details the tested handles that are approved.

| Element | Manufacturer & Product Reference |
|---------|--|
| Handles | 1. Union ASSA Abloy Lever type handle Ref. J1000RR501-RR501 – BMT/FER/F13291 |

Alternative handles are permitted providing they meet the specification given below:

- Steel, stainless steel, brass, aluminium or bronze are permitted
- Surface fixings or through fixings are permitted. If through fixed there must be no more than 0.5mm clearance between the hole and the fixing.
- The hole through the leaf to facilitate the spindle must be no greater than 20mm diameter.

The design may be either handle on rose or handle on back plate up to the following maximum sizes:

- Handle on rose with a rose diameter up to 52mm
- Handle on back plate with a back plate size up to 243mm high x 52mm wide
- Lever handle length 250mm

The handle must be compatible with the lock/latch, such that the closing action of the doorset is not impeded.

Escutcheons are permitted providing they meet the specification given below:

- Steel, stainless steel, brass, aluminium or bronze are permitted.
- Surface fixings or through fixings are permitted. If through fixed there must be no more than 0.5mm clearance between the hole and the fixing.
- The escutcheon may be up to Ø52mm overall and up to 8mm thick.

10.6 Butt Hinges

The table below details the tested butt hinges that are approved.

| Element | Manufacturer & Product Reference |
|---------|---|
| Hinges | 1. Royde and Tucker H107 Lift off Hinges – BMT/FER/F13291 |

Alternatively, Certifire approved components with the following specification are also deemed acceptable.

| Element | Specification |
|-------------------------------------|---|
| Blade height: | 90 - 120mm |
| Blade width (excluding knuckle): | 30 - 41mm |
| Blade thickness | 5 - 6mm |
| Fixings: | Minimum of 4 No. 30mm long No. 8 or No.10 steel wood screws per blade |
| Materials: | Steel or stainless steel |

In all instances, the hinges must have the following specification.

| Element | | Specification | |
|-------------------------|------------------------|-----------------------------------|---|
| Hinge Positions | 4 hinges are required: | Top | 100-200mm from the head to top of hinge |
| | | 2 nd & 3 rd | Equispaced between top and bottom or 2 nd hinge 200mm from top hinge and 3 rd hinge equally spaced between 2 nd and bottom hinge |
| | | Bottom | 150 - 300mm from the foot of leaf to bottom of hinge |
| Intumescent protection: | | See section 10.2 | |

10.7 Doorset Self Closing

Doorset automatic self-closing can be provided by:

- Overhead face fixed closers

Automatic doorset self-closing devices such as transom mounted, and offset pivots used with floor springs or concealed closers of any form are not considered acceptable for use with the ESD Ac43 doorset range.

10.7.1 Overhead Face Fixed Closer

The table below details the tested overhead face-fixed closers that are approved.

| Element | Manufacturer & Product Reference |
|-----------------------------|---------------------------------------|
| Overhead face-fixed closers | 1. ASSA Abloy DC200A – BMT/FER/F13291 |

Alternatively, components with the following specification are also deemed acceptable.

- Certifire approved overhead face-fixed closers for 60-minute fire resistance applications on 54mm thick timber door and timber frames.

Note:

It must be ensured that the closer is of sufficient strength and power to ensure the door leaf/leaves fully engage into the frame reveal.

10.8 Bolts

10.8.1 Flush Bolts

Flush bolts may be incorporated centrally into the top and bottom of one meeting edge, providing the following maximum dimensions are not exceeded and the components are fitted opposite the edge fitted with intumescent strips:

- 203mm long x 34mm deep x 20mm wide.

Flush bolts must be steel, and the mortice must be as tight to the mechanism as is compatible with its operation. All edges of the mortice of the keep and body must be protected with intumescent gaskets as specified in section 10.2. Alternatively, the hardware manufacturers tested gaskets may be used.



Flush bolt installation and intumescent protection

10.8.2 Surface Mounted Face Fixed Bolts

Surface mounted face fixed bolts constructed from steel, stainless steel or bronze may be fitted to the top and bottom of one leaf within a double doorset design, providing the following maximum dimensions given below are not exceeded and the components are fitted at least 50mm from the meeting edge:

- 300mm long x 20mm wide (footprint).

Intumescent protection is not required.

10.9 Non-Essential Hardware

Only the following items of non-essential hardware are permitted in addition to the prescribed essential hardware as detailed within section 10.3.

10.9.1 Pull Handles

Steel, stainless steel or bronze handles may be surface-fixed or bolted through the door leaf, providing the length is limited to 1200mm between the fixing points. If through fixed, there must be no more than 1mm clearance between the hole and stud.

The above scope of application is provided as in the opinion of Warringtonfire they will not significantly affect the fire resistance performance of the doorset being considered. This is on the basis of the items being surface mounted away from the edge of the door leaf, therefore unlikely to influence the junction between door leaf and frame. Furthermore, they are generally of lightweight construction, meaning that they are unlikely to destabilise the doorset and therefore cause adverse deflection under test conditions. Lastly, the surface mounted arrangement of the features means no material is removed in terms of the overall thickness of the door leaf beyond the footprint of the item, therefore burn through of the leaf would not be expected.

10.9.2 Push Plates & Kick Plates

Components with the following specification are deemed acceptable as in the opinion of Warringtonfire they will not significantly affect the fire resistance performance of the doorset being considered. This is on the basis of the items being surface mounted away from the edge of the door leaf, therefore unlikely to influence the junction between door leaf and frame. Furthermore, they are generally of lightweight construction, meaning that they are unlikely to destabilise the doorset and therefore cause adverse deflection under test conditions. Lastly, the surface mounted arrangement of the features means no material is removed in terms of the overall thickness of the door leaf beyond the footprint of the item, therefore burn through of the leaf would not be expected.

Approved specification:

- Polymeric or metal face-fixed hardware such as push plates and kick plates up to 2mm thick may be surface fitted to the doorset. These items of hardware are permitted up to a maximum of 20% of the door leaf area if mechanically fixed and a maximum of 30% if bonded with a contact or other thermally softening adhesive.
- Plates must not return around the door edges.
- In all cases plates meeting the above specification shall not be applied under glazing beads or door stops.

10.9.3 Security Viewers

Up to 2no. viewers are permitted within a single door leaf, viewers are to be positioned no closer than 100mm to door edges, glazed apertures or any other hardware component.

Components with the following specification are deemed acceptable.

- Door security viewers with brass or steel bodies of a diameter less than or equal to 15mm may be used provided that the through-hole is bored tight to the case of the viewer (maximum tolerance +1 mm). Lenses must be glass and the item must be protected with a tested acrylic intumescent mastic and / or a 0.5 – 1.0mm thick graphite based intumescent wrap.

10.9.4 Door Selectors

These items are suitable in the following applications only:

Configurations: All double leaf door configurations

These may be freely applied, provided that they are not invasive in the leaf edges or door frames, and they do not interfere with the self-closing action of the door leaf. Products that are invasive will require fire resistance test/assessment evidence to support their use.

10.9.5 Environmental Seals

Two different environmental seals have been successfully tested as part of the ESD Ac43 doorset design. The Norseal 710 and Norseal 788 seals were both fitted and successfully tested in report BMT/FER/F13291.

On this basis, PVC & silicon based flame retardant acoustic, weather and dust seals (for example those referenced above) may be fitted to this doorset design without compromising the fire resistance performance, providing their fitting does not interfere with the activation of the intumescent seals or hinder the self-closing function of the leaves.

10.9.6 Threshold drop Seals

The below detailed drop seals were successfully tested in BMT/FEP/F14207 Revision B and BMT/FEP/15288 Revision A. Based on the successful testing of the drop down seals they have been considered acceptable for use with the ESD Ac43 doorset design. This is based on the fact that both drop down seals have demonstrated a performance over 60 minutes fire resistance performance in a door leaf which is thinner than that used within the ESD Ac43 doorset design. Therefore, the increased thickness of the ESD Ac43 doorset design is believed to in fact improve the fire resistance performance observed with the thinner door leaves. The evidence demonstrates the performance of the drop down seals without additional intumescent protection and therefore, it is not required.

Note, if a rebated drop seal is fitted to the doorset then flush bolts, if approved, may not be fitted to the bottom of the doorset.

| Product | Manufacturer |
|----------|----------------------------|
| ST422 | Sealed Tight Solutions Ltd |
| ST422 GT | Sealed Tight Solutions Ltd |

Alternative drop down seals are not permitted.

10.9.7 Knockers, Numerals & Signage

Components with the following specification are deemed acceptable as in the opinion of Warringtonfire they will not significantly affect the fire resistance performance of the doorset being considered. This is on the basis of the items being surface mounted away from the edge of the door leaf, therefore unlikely to influence the junction between door leaf and frame. Furthermore, they are generally of lightweight construction, meaning that they are unlikely to destabilise the doorset and therefore cause adverse deflection under test conditions. Lastly, the surface mounted arrangement of the features means no material is removed in terms of the overall thickness of the door leaf beyond the footprint of the item, therefore burn through of the leaf would not be expected.

Approved specifications:

Knockers:

- Steel, stainless steel, aluminium or bronze knockers, may be surface fixed or bolted through the door leaf, providing they are fitted no closer than 75mm from the leaf edge, other elements of building hardware or to any glazing and are no greater than 200mm high x 120mm wide. If through fixed, there must be no more than 1mm clearance between the hole and stud. It is only permitted to fit 1No. knocker to any one doorset.

Numerals & Signage:

- Steel, stainless steel, aluminium or bronze numerals or signage may be surface fixed to the door leaf, providing they are fitted no closer than 35mm from the leaf edge, other elements of building hardware or to any glazing. The dimension of each numeral or sign must be no greater than 200mm high x 100mm wide x 4mm thick. Up to 5No. numerals or signs may be applied to a doorset, numerals and signs may be applied adjacent to each other providing the 35mm from other elements as detailed above is maintained.

10.9.8 Security Chains

Components with the following specification are deemed acceptable as in the opinion of Warringtonfire they will not significantly affect the fire resistance performance of the doorset being considered. This is on the basis of the items being surface mounted with fixings positioned away from the edge of the door leaf and therefore unlikely to influence the junction between door leaf and frame. Furthermore, they are generally of lightweight construction, meaning that they are unlikely to destabilise the doorset and cause adverse deflection under test conditions. Lastly, the surface mounted arrangement of the features means no material is removed in terms of the overall thickness of the door leaf beyond the footprint of the item, therefore burn through of the leaf would not be expected.

Approved specification:

- Metallic security chains may be surface fixed to the face of the door leaf and frame, providing they are fitted such that they do not interfere with the junction between the leaf edge and the frame, and no material is removed in order to facilitate the fitting of the security chain. Screws to affix the security chain shall be no greater than 25mm long.

10.9.9 Fire Door Identification Plates

Plastic or metal fire door identification plates may be glued or screwed to the face of the door leaves providing they are fitted no closer than 35mm from the leaf edge, other elements of building hardware or to any glazing. The dimension of any applied plate must be no greater than 100mm high x 100mm wide x 3mm thick.

These may be required to identify the following:

- a) To be kept closed when not in use (Fire Door Keep Shut)
- b) To be kept locked shut when not in use (Fire Door Keep Locked Shut)
- c) Held open by an automatic release mechanism or free swing device (Automatic Fire Door Keep Clear).

When applied to a door leaf the plate shall be surface mounted to the face without removing material from the leaf.

10.9.10 Panic Hardware

Certifire approved panic hardware may be fitted, providing the installation does not require the removal of any timber from the leaf, stop or frame reveal and it does not interfere with the self-closing action of the door leaf.

The fitting of panic hardware is not considered to change the latching arrangement of the doorset and therefore the permitted leaf size shall be established using unlatched doorset configurations as detailed within section 4.5.5 or 4.5.6.